

**MUNICIPAL CORPORATION OF DELHI  
PUBLIC HEALTH DEPARTMENT, CENTRAL ZONE  
SHIV MANDIR MARG, LAJPAT NAGAR, NEW DELHI**

No.DHO/CNZ/2025/D 1498

Dated: 18/11/2025

**HEALTH CERTIFICATE**

In further continuation of this, a School Health Certificate was issued vide letter no DHO/CNZ/2015/D-1799 dated 27.11.2024. The school premises were re-inspected by officials of the Public Health Department in the presence of school management, and found to be in sanitary and hygienic condition from a health point of view. The details are as follow:

**Name of the school: M/s Hamdard Public School.**

**Address of School: Gali No.-15 Ratia Marg, Talimabad, Sangam Vihar, New Delhi-110080**

**Shifts: One                      Timing: MORNING**

**No. of Students :              Boys:1644              Girls:1491              Total:-3135**

**No. of Staff (Teachers) : Female: 103              Male: 54              Total: 15**

That the accommodation provided for the class rooms as calculated.

- |    |  |           |
|----|--|-----------|
| 1. | (A) On floor space is sufficient   | Yes       |
|    | (B) On Cubic space is sufficient   | Yes       |
| 2. | That the classrooms are well ventilated                                      | Yes       |
| 3. | That the classrooms are kept neat and clean                                  | Yes       |
| 4. | That the classrooms are well lighted   | Yes       |
| 5. | That the drinking water is wholesome   | Wholesome |
| 6. | That the latrines arrangement is adequate and there are sufficient latrines. |           |
| 7. | That urinals arrangement is adequate and there are sufficient urinals        |           |

This certificate is issued for sanitary and hygienic conditions from the health point of view of the school premises. This certificate has no bearing structure stability/ unauthorized construction and fire safety.

  
Dy. Health Officer  
Central Zone


**Deputy Health Officer  
Central Zone, MCD**



# Shanker Laboratories

F-277, Flatted Factory Complex, Captain Gaur Marg,  
(Near Okhla NSIC Metro Station), Okhla, New Delhi - 110020

*Known for Excellency in Testing*



## TEST REPORT

Dated: 29 July 2025

Report No: 32125

**Name & contact of Customer:** M/s. Hamdard Public School Talimabad Sangam Vihar  
New Delhi -110080

**Dt. of Receipt:** 24.07.2025

**Nature of Sample:** Said to be Water

**Sample ID:** Raw Water

**Test period:** 24- 29 July 2025

**Laboratory Mark:** SL 32125-250724

S. No	Parameter	Unit	Results	Test Method	Acceptable Limits as per IS: 10500-2012	Conformity of sample Yes / No
1	pH@25°C	--	7.51	IS 3025-Pt 11: 2022	6.5-8.5	Yes
2	Total Hardness as CaCO <sub>3</sub>	mg/L	688.0	IS 3025-Pt 21: 2023	Not more than 200 mg/L	No
3	Calcium as Ca	mg/L	209.60	IS 3025-Pt 40: 2024	Not more than 75 mg/L	No
4	Magnesium as Mg	mg/L	39.85	IS 3025-Pt 46 : 2023	Not more than 30 mg/L	No
5	Total Alkalinity CaCO <sub>3</sub>	mg/L	372.0	IS 3025-Pt 23 : 2023	Not more than 200 mg/L	No
6	Total Dissolved Salts TDS@ 180 °C	mg/L	960.0	IS 3025-Pt 16: 2023	Not more than 500 mg/L	No
7	Chloride Cl	mg/L	207.48	IS 3025-Pt 32: 2019	Not more than 250 mg/L	Yes
8	Turbidity	NTU	1.0	IS 3025-Pt 10:2023	Not more than 1	Yes
9	Odour	Agreeable /Not Agreeable	Agreeable	IS 3025-Pt 5:2018	Agreeable	Yes
10	Iron Fe	mg/L	0.2	IS 3025-Pt 53: 2024	Not more than 0.3 mg/L	Yes
11	Specific Conductivity	µs/cm	1435.0	IS 3025-Pt 14: 2023	-	-

### Conditions:

1. Results given above refer only to the sample supplied.
2. The report is being issued on the specific understanding that Shanker Laboratories will not in any way be involved in any action following the interpretation of the above results.
3. This report shall not be reproduced, except in full, without the written permission of CEO, Shanker Laboratories, New Delhi..
4. Retention period of sample is 30 days as per ensuring the report.

Mrs. Pooja

Reviewed by

Mr. Neeraj Katwal

Authorised Signatory

NABL Accredited (TC-15979).

UDYAM-DL-08-0030440

Phones : 9999993311, 9999990481, 9999552799, 9811505398

Email : shankerlaboratories@gmail.com

Website : www.shankerlaboratories.com



# Shanker Laboratories

F-277, Flatted Factory Complex, Captain Gaur Marg,  
(Near Okhla NSIC Metro Station), Okhla, New Delhi - 110020

*Known for Excellency in Testing*

## TEST REPORT

Dated: 29 July 2025

Report No: 32125

**Name & contact of Customer:** M/s. Hamdard Public School Talimabad Sangam Vihar  
New Delhi -110080

**Dt. of Receipt:** 24.07.2025

**Nature of Sample:** Said to be Water

**Sample ID:** Raw Water

**Test period:** 24- 29 July 2025


**Laboratory Mark:** SL 32125-250724

S. No	Parameter	Unit	Results	Test Method	Acceptable Limits as per IS: 10500-2012	Conformity of sample Yes / No
1	Color Hz	Hz	1	IS 3025-Pt 4 2021	Not more than 5 Hz	Yes
2	Sulphate SO <sub>4</sub>	mg/L	384.0	IS 3025-Pt 24: Sec 1:2022	Not more than 200 mg/L	No
3	E Coli	Absent/Present	Absent	IS 1622: 1981	Absent	Yes
4	Total Coliform	Absent/Present	Absent	IS 1622: 1981	Absent	Yes

### Conditions:

1. Results given above refer only to the sample supplied.
2. The report is being issued on the specific understanding that Shanker Laboratories will not in any way be involved in any action following the interpretation of the above results.
3. This report shall not be reproduced, except in full, without the written permission of CEO, Shanker Laboratories, New Delhi..
4. Retention period of sample is 30 days as per ensuring the report.

  
Mrs. Pooja  
Reviewed by

  
Mr. Neeraj Katyal  
Authorised Signatory

---- End of Report----

UDYAM-DL-08-0030440

Phones : 9999993311, 9999990481, 9999552799, 9811505398

Email : shankerslaboratories@gmail.com

Website : www.shankerslaboratories.com